

## TESTING / CONSULTANCY REPORT

Civil-112/MKT/AA/Env.Engg.Lab./TR 254/205122/580

Date: 22/02/19

To,  
The Bursar  
Scindia Kanya Vidyalaya  
Moti Mahal Road  
Gwalior (M.P.) - 474007



**MITS Dispatch**

Ref: Your letter No. Nil dt. 14-02-2019.

Sub: Testing of Water Sample's of Administration Block, Academic Block & Hostel Block for drinking purpose.

Dear Sir,

Please find herewith the testing report of the water sample's sent by you vide above mentioned reference & subject.

S.No.	Parameters/Tests	Laboratory Results		
		Administration Block	Academic Block	Hostel Block
1.	Colour	Absent	Absent	Absent
2.	Odour	Un-objectionable	Un-objectionable	Un-objectionable
3.	Taste	Un-objectionable	Un-objectionable	Un-objectionable
4.	pH Value	7.5	7.4	7.7
5.	Acidity	1.5 mg/l as CaCO <sub>3</sub>	2.5 mg/l as CaCO <sub>3</sub>	1.5 mg/l as CaCO <sub>3</sub>
6.	Alkalinity	1.0 mg/l as CaCO <sub>3</sub>	2.0 mg/l as CaCO <sub>3</sub>	1.5 mg/l as CaCO <sub>3</sub>
7.	Suspended Solids	NIL	NIL	NIL
8.	Dissolved Solids	15 mg/l	53 mg/l	12 mg/l
9.	Total Solids	15 mg/l	53 mg/l	12 mg/l
10.	Chlorides(Cl <sup>-</sup> )	15 mg/l	15 mg/l	10 mg/l
11.	Hardness	5 mg/l as CaCO <sub>3</sub>	17 mg/l as CaCO <sub>3</sub>	12 mg/l as CaCO <sub>3</sub>

- The above tested Parameter of water sample complies with the standard laid down in IS:10500-1991.
- Testing charges of Rs. 12426/- vide Receipt No. 26 dated 15.02.2019
- Sample received on: 15-02-2019
- Testing date / Report generated on: 18-02-2019 / 18-02-2019.

*Aditya*  
18.2.2019  
(Prof. I/c PHE Lab)

*MK*  
(H.C.E.D.) 18/02/19

Forwarded:

This Testing / Consultancy report is forwarded on the recommendations of the Department Responsibility of Test / Consultancy Report lies with the concerning department.

12426/-  
RNo 26  
15/2/19  
Book No. MITS TCR/ X

*Opun P*  
DIRECTOR 20.2.19  
Sr. No. 2017 57