

DHAV INSTITUTE OF TECHNOLOGY & SCIENCE, GWALIOR

NAAC ACCREDITED WITH A++ GRADE

Gola Ka Mandir, Gwalior (M.P.) - 474005, INDIA

Ph.: +91-751-2409300, E-mail: director@mitsgwalior.in, Website: www.mitsgwalior.in

TESTING / CONSULTANCY REPORT

Civil/MKT/AKA/Env.Engg.Lab./ TR No. 331/No To7009/313

To.

Scindia Kanya Vidyalaya, Moti Mahal Road, Gwalior MP - 474007

Mob.: 9522037279

Email: principal@skvgwalior.org

Ref. No.:

Nil, Dated 31.01.2024

Sub:

Testing of sealed Water sample (RO) for drinking purpose

Dear Sir,

Kindly find enclosed herewith the Water Quality sealed (RO Water Sample) Test report and Safe drinking water and sanitary condition certificate for your Vidyalaya.

- Testing and visiting charge of Rs. 9204/- deposited vide UTR No. M-N038242872137510 dated 07.02.2024.
- Sample collected on 04-02-2024.
- Site visit /Testing date on 04-02-2024/05-02-2024.
- Report generated on 13.02.2024

(Prof. I/c PHE Lab)

(H.C.E.D.)

Forwarded:

This Testing / Consultancy report is forwarded on the recommendations of the Department Responsibility of Test/Consultancy Report lies with the concerning department.

Testing/Consultancy Amount Paid

TENO NO38242872137511

Date. 7/2/24

Finance cum Accounts Of

MITS, GWALIOR TESTING / CONSULTANCY REPORT MITS, GWALIOR TESTING / CONSULTANCY REPORT

Book No.: MITS TCR/ XXXXIII

Sr. No.: 2023



ADHAV INSTITUTE OF TECHNOLOGY & SCIENCE, GWALIOR

(A Govt. Aided UGC Autonomous Institute, Affilated to RGPV, Bhopal, M.P.)

NAAC ACCREDITED WITH A++ GRADE

Gola Ka Mandir, Gwalior (M.P.) - 474005. INDIA

Ph.: +91-751-2409300, E-mail: director@mitsgwalior.in, Website: www.mitsgwalior.in

TESTING / CONSULTANCY REPORT

Civil/MKT/AKA/Env.Engg.Lab./ TR No. 331/Ref. Hologram No. To 7009 313

To.

Scindia Kanya Vidyalaya,

Moti Mahal Road,

Gwalior MP - 474007

Mob.: 9522037279

Email: principal@skvgwalior.org

Ref. No. Nil Dated 31.01.2024

Sub.

Testing of sealed Water sample (RO) for drinking purpose

Dear Sir.

Please find herewith the test report of the sealed water sample collected from RO machine of your Vidyalaya during site visit on 04.02.2024 vide above mentioned reference & subject.

TESTING REPORT

IESTING REPORT		
S. No.	Parameters/Tests	Laboratory Results
1	Temperature	23.4°C
2	Turbidity	Nil
3	Colour	Absent
4	Odour	Un-objectionable
5	Taste	Un-objectionable
6.	pH Value	6.70
7	Acidity	20.0 mg/l as CaCO ₃
8	Alkalinity	46.0 mg/l asCaCO₃
9	Total Solids	110 mg/l
10	Dissolved Solids	110 mg/l
11	Suspended Solids ·	Nil
12	Chlorides(Cl-)	32.0 mg/l
13	Hardness	60 mg/l asCaCO ₃
10		

Remarks:


The above tested Parameters of water sample complies with the drinking water standard as laid down in IS:10500-2012. Hence it can be commented that Water Sample is found fit for drinking purpose only on the above tested parameters.

(Prof. I/c PHE Lab)

Forwarded:

This Testing / Consultancy report is forwarded on the recommendations of the Department Responsibility of Test / Consultancy Report lies with the concerning department.

Sr. No.: 2023



MADHAV INSTITUTE OF TECHNOLOGY & SCIENCE, GWALIOR

(A Govt. Aided UGC Autonomous Institute, Affilated to RGPV, Bhopal, M.P.)

NAAC ACCREDITED WITH A++ GRADE

Gola Ka Mandir, Gwalior (M.P.) - 474005, INDIA

Ph.: +91-751-2409300, E-mail: director@mitsgwalior.in, Website: www.mitsgwalior.in

TESTING / CONSULTANCY REPORT

Civil/MKT/AKA/Env.Engg.Lab./ TR No. 331/Ref. Hologram No. To 7009

Date: 16 2 2024

To, Scindia Kanya Vidyalaya, Moti Mahal Road, Gwalior MP - 474007 Mob.: 9522037279

Email: principal@skvgwalior.org

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by Prof. Aditya K. Agarwal, Assistant Professor from Civil Engineering Department, MITS, Gwalior inspected the Scindia Kanya Vidyalaya, Moti Mahal Road, Gwalior on 04.02.2024 and found that the Scindia Kanya Vidyalaya, Moti Mahal Road, Gwalior has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus as per norms prescribed by the Central/State/U.T. Govt.

The above certificate is valid for a period of <u>01 year (February 2024 to January 2025)</u>

Remarks:

CONSULTANCY REPORT

MITS, GWALIOR TESTING / CONSULTANCY

This is as per the physical visit conducted at school on 04/02/2024 and water quality testing conducted at our Institute, the water quality test report for the same is annexed with this certificate.

Book No.: MITS TCR/ XXXXIII

Asst. Prof.

Prof. A.K. Agarwal (Prof. I/c PHE Lab)

M.I.T.S. GWO.

Sr. No.: 2023

MITS, GWALIOR TESTING / CONSULTANCY REPORT MITS, GWALIOR TESTING / C